



Highland County Health Department
PO BOX 558
Monterey, VA 24465
(540) 468-2270 Voice
468-2502 Fax

Private Well Record of Inspection

Health Department ID Number: 145-14-0005

Tax Map/GPIN: 31A(1)A

Owner Name: Mary Tate Swecker & Robert Dunn

Owner Address: P O Box 515

Monterey, VA 24465

Private Well Facility Information

Property Address: Spruce St

County: Highland

Well Driller: BRIAN D LESTER, 2719490

Date construction started: June 27, 2014

Subdivision:

Section Block Lot

Well Class: Class IIIC

Water Well Completion Report Received: Yes

Location Information

Building Sewer: 50 feet

Pretreatment Unit: 50 feet

Conveyance System: 50 feet

Comments:

Soil Absorption System: 100 feet

Property Line: 50 feet

Other Distance: Other feet

Construction Information

Total depth of well: 225 feet

Type of casing: Galvanized Steel

Depth of casing: 160 feet

Diameter of casing: 4 inches

Casing extends: 18 in. above ground

Annular Space: sealed with bentonite to a depth of 20 feet, Poured from Surface

Comments: Casing: 0-160' steel / well liner 0-220' 4" sch 40

Pitless adapter used:

Pitless properly installed:

Pitless properly vented:

Type of Well Seal: Well cap

Screens: constructed of

Quantity & Quality

Yield and drawdown determined by continuous pumping of 30 minutes

Yield: 20 gpm

Drawdown:

Static Water Level: 100 feet

Type of storage:

Comments:

Sample tap provided: Yes

Sample collected: Yes

Result of samples: Satisfactory

Date of Sample: November 18, 2014

Satisfactory Construction: Yes on February 11, 2015

Well Approved for Use: Yes on February 11, 2015

Signed February 11, 2015


Tim Abbott,



Churchville Pump Service
Attn: Daniel Griffin Jr
P O Box 52
Churchville, VA 24421

Analytical Results

V4806126

EnviroCompliance Laboratories, Inc.
Post Office Box 919
Verona, Virginia 24462
(540) 248-1311
Fax: (540) 248-4804
www.envirocompliance.com
eciverona@envirocompliance.com

Project No. : 31A-(1)-A/145-14-0005
Project Name : Robert Dunn
Date Received: August 20, 2014
Date Sampled : August 20, 2014
Time Sampled : 12:05
Date Issued : August 22, 2014

Lab # V4806126 - 1(A)/Sample ID : 170 Spruce St

Parameter	Result	Unit	Date/Time Prepared	Date/Time Analyzed	Method	Analyst
Total Coliform	Negative		08-20/2014	8-21/1030	9223	TGH
E. coli	Negative		08-20/2014	8-21/1030	9223	TGH

This water sample meets the standards for total coliform bacteria set by the state health department.

Tax Map No. : 31A-(1)-A
Health Dept. No.: 145-14-0005

Registration Number: 00140

Sara G. Hostetter

Manager

Page 1 of 2

© EnviroCompliance 2014

This report is only valid as the complete digital document authored by EnviroCompliance Labs, Inc.



\\sars\V4806126.pdf